



CONSTRUCTED WETLANDS FOR WASTEWATER TREATMENT IN UGANDA

Markus Lechner

EcoSan Cub Austria





BACKGROUND

- *WWTP Matany Hospital (1997-1998)*
- *WWTS Maracha Hospital (2001-2003)*
- *WWTS Naggalama Hospital (2002-2005)*
- *WWTS Kalungu Girls Secondary School (2003-2004)*
- *WWTS Kanawat Health Centre (2003-2004)*
- *WWTS Kitgum St. Joseph Hospital (2005-2008)*
- *WWTS Nyapea Hospital (2006)*






STANDARDS

COD	100 mg/l
BOD₅	50 mg/l
NH₄-N	10 mg/l
N_{tot}	10 mg/l
P_{tot}	10 mg/l
PO₄-P	5 mg/l

The National Environment (Standards for Discharge of Effluent into Water or on Land) Regulations, S.I. No 5/1999




HORIZONTAL FLOW CWS





VERTICAL FLOW CWS



PRE-TREATMENT



Constructed Wetlands in U

PRE- TREATMENT



Constructed Wetlands in U



















PERFORMANCE

VERTICAL FLOW CW		MATANY			MARACHA		
Parameter		#	Average	Stdev	#	Average	Stdev
Physico-chemical paramters							
COD	mg/L	6	86	48	5	130	70
BOD5	mg/L	4	20	14	2	14	2
NH4-N	mg/L	3	1,4	0,5	5	43,4	28,2
PO4-P	mg/L	5	7,8	1,9	6	10,0	14,7
SO4-S	mg/L	3	34,7	6,1	3	26,7	6,0
Turbidity	NTU	4	7,1	9,1	4	17,0	15,6
Ph value	-	5	7,1	0,7	5	6,8	1,2
El. conductivity	μS/cm	5	1550	147	5	1841	360
Temperature	°C	4	25,8	2,1	4	26,2	1,8



PERFORMANCE

HORIZONTAL FLOW CW		KANAWAT			KALUNGU		
Parameter		#	Average	Stdev	#	Average	Stdev
Physico-chemical paramters							
COD	mg/L	6	87	31	5	121	31
BOD5	mg/L	3	22	4	3	65	7
NH4-N	mg/L	6	46,6	27,3	5	29,2	15,1
PO4-P	mg/L	5	5,8	2,4	4	7,5	5,5
SO4-S	mg/L	3	43,3	9,0	2	34,5	6,4
Turbidity	NTU	4	18,8	22,1	3	34,0	27,6
Ph value	-	5	7,7	0,2	4	7,4	0,6
El. conductivity	μS/cm	5	2046	375	4	1145	332
Temperature	°C	4	24,4	2,6	5	23,9	2,5



CONCLUSIONS

- *most effective and efficient treatment system among near natural systems*
- *space requirement significantly less compared to ponds/lagoons with better performance*
- *o&m possible even in remote areas*
- *o&m improved in case of additional benefits (e.g. irrigation - Matany, Kanawat; compost - Maracha)*
- *investment cost app. 100 EUR/PE*
- *additional research required for further optimisation (design)*

- *HF appropriate for carbon removal*
- *VF appropriate for carbon removal and nitrification*



Thank you!